

**Watermark La Reserve  
APN 104-240-22**

**Amendment A**

**Wildfire Fire Safe Plan**

**Prepared for:**

**Richard Thompson**


**Prepared by:**

**CDS Fire Prevention Planning  
William F. Draper  
Registered Professional Forester  
#898  
4645 Meadowlark Way  
Placerville, CA 95667**

**April, 2006**

**Watermark La Reserve  
APN 104-240-22  
Amendment A**

**Plan Approved by:**



**Fred Russell  
Division Chief-Fire Marshall  
El Dorado Hills Fire Department**

4-17-06  
Date



**Ben Scott, Battalion Chief  
Fire Prevention  
California Department of Forestry  
and Fire Protection**

4/20/06  
Date

**Prepared by:**



**William F. Draper  
RPF 898**

4/20/06  
Date



This amendment is for the clarification of an error that was made on page 6 and page 8 of the original Watermark La Reserve Wildland Fire Safe Plan prepared January, 2006.

The secondary access from Watermark to Zee Estates is an 18 foot wide graveled road as required by the Watermark State Responsibility Area Wildfire Safety Plan prepared by Douglas R. Leisz and Eugene E. Murphy in September, 1998. This road has been built to the required standard and mis-identified by myself in the initial field inspection as a driveway serving 1410 Hidden Bridge Drive (see page 6, item 5).

Item J. on page 8 under Other Fire Safe Requirements is not required. This is the secondary access road from Watermark to Zee Estates.