Hawk View Wildfire Fire Safe Plan Amendment B

Prepared for:

BL Road, LLC.

Prepared by:

CDS Fire Prevention Planning
William F. Draper
Registered Professional Forester
#898
4645 Meadowlark Way
Placerville, CA 95667

August 12, 2017

Hawk View Amendment B

Approved by:	
Marshall Cox Fire Marshal El Dorado Hills Fire Department	8/17/17 Date
Darin McFarlan Fire Prevention California Department of Forestry and Fire Protection	8/17/19 Date
Prepared by:	
William F. Draper PRPF #898	8/12/17 Date

Hawk View

Amendment B

Purpose:

This amendment is to update and clarify the original Wildfire Fire Safe Plan and Amendment A approved in October and December 2005. There have been changes in the California Fire Code, state Fire Safe Regulations and local fire ordinances. The scope of the project remains basically the same as previously proposed. Hawk View is going to be a 114 single family lot community with 5 landscaped lots and 2 open space lots and 4 utility corridors on 40.10 acres. It is to be developed in 2 phases. A revised map is attached.

Hawk View is to be a gated community. The entrance gates and openers shall meet the requirements of El Dorado Hills Fire Department. No internal gates on the roadways shall be allowed.

This new community is in a moderate Fuel Hazard Severity Zone. All houses shall be required to have a NFPA 13D fire sprinkler system.

Lots C, D1, D2, E, and F will be landscaped and maintained. Lots G, H, I, and J are utility corridors. Lot A is designated open space with access from the end of Court "E". Lot B is also designated open space with access from Court "A" and Road "B". Lot "B" may be landscaped. Access to the open space shall adhere to the requirements set out in Appendix C and as amended to include automatic gate openers meeting fire departments standards and rolled curb and gutter may be used in-lieu of a "break" in the curb.

Requirement "I" of section 6 "Other fire Safe Requirements" found on page 8 of the original Wildfire Fire Safe Plan is no longer required.

All roads and driveways shall meet the 75,000 pound weight requirement for emergency vehicles as specified in the California Fire Code.

Non-combustible fencing shall be required along the back of lots 57-74. Lots 56 and 57 shall also have non-combustible fencing adjacent to the open space along the side yards. Lot 35 shall have a side yard non-combustible fence in the event that Lot "B" remains native (not landscaped). No pedestrian gates are required.

All lot setbacks shall be as agreed to and set in the Conditions of Approval dated April 28. 2016.

All road widths shall comply with the Conditions of Approval. All cul-de-sacs shall have a minimum turn-around radius of 50'.

Secondary access shall be provided during all phases of home construction.

All other conditions in the original Wildfire Fire Safe Plan and Amendment A shall remain in effect unless superseded by this Amendment B and the Conditions of Approval dated April 28, 2016.

As previously stated in Amendment A dated December 2005, pedestrian gates are not required.



